STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120525
Permit No. 83543T
Basin 177

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69109

1. OWNER Scott & Laurel Egbert
MAILING ADDRESS HC 60 Box 125
Wells, NV 89835

ADDRESS AT WELL LOCATION H.C. 60 Box 135
Wells, NV 89835
Subdivision Name: County: ELKO

2. LOCATION NW¼ NW ¼ Sec 4 T 35 N S R 62 E
PERMIT/WAIVER No. 83543T (Issued by Water Resources) 008-320-006 (Parcel No.)

Latitude 40.951822° N
Longitude 114.987156° W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Sand		0	10	10
tan Sand, gravel (¼")		10	230	220
tan Clay		230	260	30
Blue Clay		260	265	5

1/AD27
40.951898°N
114.986277°W

RECEIVED 2014 AUG 15 PM 1:45 STATE ENGINEERS OFFICE

Date started: July 30, 20 14
Date completed: August 12, 20 14

7. Water Level
Static water level: 40 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
350		7 HRS.
deepened on 4-12-15	and	worked

9. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	265	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.375	+2	265

Perforations:
Type of perforation Mill
Size of perforation 5/32 X 2 1/2 X 32
From 105 feet to 265 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 265 ☐ Pumped ☒ Poured
Type: 1/2"
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling (Contractor)
Address PO Box 965 (Contractor)
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2468
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date August 13, 2014

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627