STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120538
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37382
WELL NAME (if applicable): MW-33

1. OWNER/CLIENT NAME Clark County Right of Way
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas, NV 89101

DETAILED ADDRESS AT WELL LOCATION 35' South of Bell Dr. & Cameron St. on Cameron
Subdivision Name: County: Clark

2. PLS LOCATION NE ¼ NW ¼ 30 Sec 21S N/S 61 E
PERMIT/WAIVER NO. 162-30-199-020
Issued by Water Resources Current Parcel No.

Latitude 36 05'56.30"N UTM E ☐ NAD 27
Longitude 115 12'13.82"W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Fill			1	3	2
Sandy Gravel			3	14	11
Caliche			14	15	1
Silty Sand			15	26	11
Caliche			26	29	3
Silty Sand			29	44	15
Caliche			44	50	6
Silty Sand			50	70	20

Date started: 3-Apr, 20 14
Date completed: 4-Apr, 20 14

9. WELL CONSTRUCTION
Depth Drilled: 70 Feet Depth Cased: 70 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	70	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		Sch 40	0	70

PERFORATIONS:
Type of perforation: Factory Slotted
Size of perforation: 0.02
From 40 Feet To 70 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	1	to 36	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	36	to 38	☐ Pumped	☒ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	38	to 70	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 55 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
		.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling L.P. (Contractor)
Address 4590 Copper Sage St., Las Vegas, NV 89115 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: C23-0073966
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2381
Signed: (By driller performing actual drilling on site or contractor)
Date: 5-5-14

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY

36.099001
-115.203006 1

NAD 27

SCANNED/DW/NSBC RECEIVED MAY 05 2014