STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120542
Permit No.
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37254

1. OWNER ALLEN ROSENBERG
MAILING ADDRESS 228 DRAPER AVE
WARWICK RI 02889

ADDRESS AT WELL LOCATION 3710 S NESS ST
PAHRUMP
Subdivision Name: PAHRUMP VLY ESTATES County: NYE

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 20S N/S R. 53 E/W
PERMIT/WAIVER No. 36-504-04 (Issued by Water Resources) Parcel No.

Latitude N36°09'54.7" Longitude W116°03"56.5"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	20	20
CALICHIE		20	25	5
CLAY		25	40	15
CALICHIE		40	45	5
CLAY		45	80	35
CALICHIE	WB	80	90	10
CLAY		90	100	10
CALICHIE	WB	100	110	10
~~CLAY~~ Gravel	WB	110	135	25

DCNR/DWR/SNBO
RECEIVED
JUL 11 2014

Date started: 9-Jul, 20 14
Date completed: 9-Jul, 20 14

9. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9-7/8	Inches	0	Feet	130	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	135

Perforations:
Type of perforation SSCREEN
Size of perforation .032
From 95 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 480 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 135 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 67 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on site or contractor)
Date 7/9/2014

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

36.165233
-116.064834
NAD 27