STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120549
Permit No.
Basin No. 57B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70664
WELL NAME (If applicable): AD-14-1

1. OWNER/CLIENT NAME Round Mountain Gold Corporation
MAILING ADDRESS PO Box 480, Round Mountain, Nv 89045

DETAILED ADDRESS AT WELL LOCATION Round Mountain Mine
Subdivision Name: County: Nye

2. PLS LOCATION SE ¼ SW ¼ 19 Sec 10N N/S 44 E
PERMIT/WAIVER NO. M/O-1932 (Issued by Water Resources) Current Parcel No.

Latitude UTM E 492734 ■ NAD 27
Longitude UTM N 4284003 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE Angle Drain
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
■ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ■ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Hard Limestone		160'	0	560'

Date started: July 28th, 20 14
Date completed: July 31st, 20 14

9. CONSTRUCTION
Depth Drilled: 560' Feet Depth Cased: 560' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.75	Inches	0	Feet	20	Feet
6.5	Inches	20	Feet	560	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.69	.154	+18"	560

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

■ Neat Cement	0'	to 54'	■ Pumped	☐ Poured	
☐ Cement Grout		to	☐ Pumped	☐ Poured	
☐ Concrete Grout		to	☐ Pumped	☐ Poured	
■ Bentonite Chips	54'	to 58'	■ Pumped	☐ Poured	3/8 Hole Plug
■ Gravel Pack [> 0.2 in.]	58'	to 560'	■ Pumped	☐ Poured	1/4 x 1/8 SRI
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured	
☐ Other, explain:		to	☐ Pumped	☐ Poured	

PERFORATIONS:
Type of perforation: Slot
Size of perforation: .020

From 60'	Feet	To 560'	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

7. WATER QUALITIES
Static water level: N/A Feet below land surface
Artesian Flow: No G.P.M. 15 P.S.I.
Water Temperature: Warm ° Fahrenheit
Water Quality: Average

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15	N/A	1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear Company (Contractor)
Address PO Box 2748 Elko, NV. 89803 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2426
Signed: Jeff McMinus (By driller performing actual drilling on site or contractor)
Date: 07/31/14

RECEIVED 2014 AUG 19 AM 11:30 STATE ENGINEERS OFFICE

Nad 27
38.266505 N
117.083557 W

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1