

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT**

OFFICE USE ONLY
Log No. 120562
Permit No. _____
Basin No. 105

**PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 72071
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME ADAM FINCH
MAILING ADDRESS adam@arrowrr.com
RENO, NV 89502

DETAILED ADDRESS AT WELL LOCATION 1856 PAINTED DESSERT
GARDNERVILLE, NV 89410
Subdivision Name: _____ County: Douglas

2. PLS LOCATION NW ¼ SE ¼ 23 Sec 13 N/S 20 E
PERMIT/WAIVER NO. DOM14-13 1320-23-002-033
Issued by Water Resources Current Parcel No.

Latitude 38.972329°N UTM E _____ NAD 27
Longitude 119.702208°W UTM N _____ NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BROWN CLAY			3	8
OBSIDIAN SANDS, GRAVELS			8	63
BROWN CLAY			63	145
SMALL GRAVELS			145	195
BROWN CLAY			195	205
OBSIDIAN GRAVELS	XX		205	260
<p><u>NAD 27</u> <u>38.972421°N</u> <u>119.701200°W</u></p>				

9. INSTRUCTION
Depth Drilled: 260 Feet Depth Cased: 260 Feet

HOLE DIAMETER (BIT SIZE)				
	From	To		
<u>10 5/8</u>	Inches	0	Feet	<u>260</u> Feet
	Inches		Feet	Feet
	Inches		Feet	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>2</u>	<u>20</u>
<u>6 5/8</u>	<u>4.26</u>	<u>.216</u>	<u>20</u>	<u>260</u>
<u>SDR21</u>				

ANNULAR MATERIALS

Sanitary Seal Yes No

<input type="checkbox"/> Neat Cement	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	0	to	55	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Bentonite Chips	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Gravel Pack [> 0.2 in.]	55	to	260	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Sand Pack [< 0.2 in.]	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Other, explain:	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Date started: 1-Aug , 20 14
Date completed: 12-Aug , 20 14

PERFORATIONS:

Type of perforation: SAW CUT
Size of perforation: 3 X 3/32

From <u>220</u>	Feet	To <u>260</u>	Feet
From _____	Feet	To _____	Feet
From _____	Feet	To _____	Feet
From _____	Feet	To _____	Feet

7. WATER QUALITIES
Static water level: _____ Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905

Signed: Michael A. Hall
Driller performing actual drilling on site of Contractor
Date: 8/13/2014

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>45</u>	<u>3 HRS</u>

RECEIVED
2014 AUG 20 AM 7:58
STATE ENGINEERS OFFICE