STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120563
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72069
WELL NAME (*if applicable*):

1. OWNER/CLIENT NAME GUILLERMINA REDI
MAILING ADDRESS 2607 WADE ST
MINDEN, NV 89423

DETAILED ADDRESS AT WELL LOCATION 2607 WADE ST
MINDEN, NV 89423
Subdivision Name: County: Douglas

2. PLS LOCATION SW ¼ SE ¼ 34 Sec 14 N/S 20 E
PERMIT/WAIVER NO. DOM14-32 (Issued by Water Resources) 1420-34-810-027 (Current Parcel No.)

Latitude 39.027129*N UTM E ☐ NAD 27
Longitude 119.720754*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log # N/A
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
DG SANDS			3	68
BROWN CLAY			68	110
BROWN SILTY SANDS			110	168
DG SANDS				
BROWN SILTY CLAY			168	172
COURSE DG GRAVELS AND SANDS	XXX		172	220
NAD 27				
39.027220°N				
119.719744°W				

Date started: 30-Jul , 20 14
Date completed: 1-Aug , 20 14

7. WATER QUALITIES
Static water level: 85 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	60	3 HRS

9. INSTRUCTION
Depth Drilled: 220' Feet Depth Cased: 220' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	20
6 5/8	4.26	.216	20	220
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	60	☐ Pumped	☒ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	60	to	220	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From	180	Feet	To	220	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: (By driller performing actual drilling on site or contractor)
Date: 8/13/2014

RECEIVED 2014 AUG 20 AM 7:55 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replacing Unknown Well log