

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 120567
 Permit No. _____
 Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71870

1. OWNER Rene Hill ADDRESS AT WELL LOCATION 6080 Solar
 MAILING ADDRESS 6080 Solar Winnemucca, NV 89445
 Subdivision Name: Country Estates County: Humboldt

2. LOCATION NE 1/4 Sec 12 T35N R37E Latitude 40 55'17.7 UTM E _____ NAD 27
 PERMIT/WAIVER NO. Dom14-29 3537-12-426-012 Longitude 117 45'30.3" N _____ NAD 83/WGS 84
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------|--------------|------|-----|------------|
| Sand | | 115 | 120 | 5 |
| Gravel | | 120 | 130 | 10 |
| Clay | | 130 | 135 | 5 |
| Sand/Gravel | X | 135 | 150 | 15 |
| Clay | | 150 | 155 | 5 |
| Gravel/Sand | X | 155 | 170 | 15 |
| Clay | | 170 | 172 | 2 |
| Gravel | X | 172 | 200 | 28 |
| Clay | | 200 | 210 | 10 |

*RECEIVED
 2014 AUG 22 AM 10:46
 STATE ENGINEERS OFFICE*

Deepens unknown well log

NAD 27
40.921680°N
117.757453°W

9. WELL CONSTRUCTION

Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
6 Inches 115 Feet 215 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|--------------------|-------------------------|-------------|------------|
| <u>5</u> | <u>8</u> | <u>.188</u> | <u>115</u> | <u>215</u> |

Perforations:
 Type of perforation Factory Cut
 Size of perforation 3/32 x 4
 From 170 feet to 210 feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement Exist to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No Natural _____ to _____ Pumped Poured
 Type: _____
 Bentonite Chips: Yes No _____ to _____ Pumped Poured
 Type: _____

7. Water Level
 Static water level: 110 feet below land surface
 Artesian Flow: N/A G.P.M. N/A P.S.I.
 Water Temperature: Cool °F
 Quality: Good

8. WELL TEST DATA

| TEST METHOD: | Draw Down (Feet Below Static) | | Time (Hours) |
|------------------------------------------------------------------------------------------------------------|-------------------------------|--|--------------|
| | G.P.M. | | |
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>30</u> | | <u>3</u> |
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling, Inc.
(CONTRACTOR)
 Address 10760 S. Grass Valley Road
(CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed Chris [Signature]
 By driller performing actual drilling on site or contractor
 Date July 21, 2014