STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120597
Permit No.
Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70663

1. OWNER Quadra Robinson HD14-11
MAILING ADDRESS P.O. Box 382, Ruth, NV. 89319

ADDRESS AT WELL LOCATION Robinson Plt, Ruth, NV.
Subdivision Name: County: White Pine

2. LOCATION NE¼NW¼ Sec14T16N/ R62E
PERMIT/WAIVER NO. M/O-1931 (Issued by Water Resources) Parcel. No.

Latitude
Longitude
UTM E 675823 ☐ NAD 27
N 4347137 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other Horizontal

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Grey Limestone		0	1000	1000
6" Well Seal to 6-5/8 Casing				
Cave in from 800-1000 ft				
Nad 27				
39.255811°N				
114.461394°W				

RECEIVED 2014 SEP -2 PM 1:50 STATE ENGINEERS OFFICE

Date started: August 3, 20 14
Date completed: August 5, 20 14

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: N/A °F
Quality: N/A

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3	N/A	N/A

9. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9.875 Inches	0 Feet	20 Feet
5.5 Inches	20 Feet	1000 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.021	.25	+3	20
2.375	3.64	.188	+3.5	800

Perforations:
Type of perforation Slotted
Size of perforation .125
From +3.5 feet to 800 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on site driller 2486
Signed
By driller performing actual drilling on site or contractor
Date August 21, 2014

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com