STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120631
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70905

1. OWNER John Gaynart
MAILING ADDRESS 1179 N. Grape St.
Coquille OR 97423

ADDRESS AT WELL LOCATION Paradise Valley Estates
Winnemucca NV. 89445
Subdivision Name: County: Humboldt

2. LOCATION NE¼ NW¼ Sec 1 T 39 N/S R 38 E
PERMIT/WAIVER No. 3938-01-100-011
Issued by Water Resources Parcel No.

Latitude N41° 17.511
Longitude W117° 38.917
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | No | 0 | 5 | 5 |
| Clay Sand Gravel | No | 5 | 65 | 60 |
| Clay Sand Gravel | Yes | 60 | 160 | 100 |

NAD 27
41.291850°N
117.648617°W

Date started: 7-22, 20 14
Date completed: 7-25, 20 14

7. Water Level
Static water level: 62 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Drew Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | NA | 4 |

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 160 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | Steel | .188 | 0 | 20 |
| 6 5/8 | PVC | Sch 40 | 20 | 160 |

Perforations:
Type of perforation Slot
Size of perforation .20
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 160 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 20 to 50 ☐ Pumped ☒ Poured
Type: 3/8" chip

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 8-15-14

(Rev 06-05)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED 2014 SEP -3 AM 11:41 STATE ENGINEERS OFFICE

(NSPO 3-08) (O) 627