

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 120705  
Permit No. \_\_\_\_\_  
Basin 209

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35675

1 OWNER Phillis Free Management Trust  
MAILING ADDRESS 5010 South Valley View Blvd  
Las Vegas NV 89118

ADDRESS AT WELL LOCATION 1/2 mile west of Aikona #40  
US 93 Aikona NV  
Subdivision Name: 6 County: Lincoln

2 LOCATION NW 1/4 SE 1/4 Sec 32 T 6 R 61 E  
PERMIT/WAIVER No. R-1662 11/2-20-01  
Issued by Water Resources Parcel No.

Latitude N 37° 22.99' UTM E  NAD 27  
Longitude W 115° 09.626' N  NAD 83/WGS 84

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? yes  
If yes, what is replacement well NO? \_\_\_\_\_  
Is there an existing well log? yes  
If yes, what is NDWR well log #? 665516

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 100 Feet 100 Depth Cased Feet

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 1/4</u>	<u>Steel</u>	<u>0.188</u>	<u>0</u>	<u>100</u>

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
<u>Perforated</u>	<u>1/2" x 8"</u>	<u>5.2</u>	<u>feet to</u>	<u>100</u>

If casing was left in place, please show where additional perforations were made:  
Additional Perforations:  
Type of perforator used: Waiver R-1662

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL  
Static water level 25 feet below land surface  
Artesian flow 5 G.P.M. poor P.S.I.  
Water temperature cold °F clarity

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<u>0</u>	<u>feet to</u>	<u>100</u>	<u>Neat cement</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments  
Pumped Neat Cement in well  
from bottom up consisting of  
approx 208 gals water and  
3,700 LBS of cement cut  
casing off at surface

DCNR/DWR/SNB  
RECEIVED  
SEP 09 2014

Neat Cement Fluid Weight \_\_\_\_\_ lbs/gal 5.2 gals per 94lb cement  
Bentonite Grout 0 % bentonite 0  
Date Started 9-2-2014  
Date Completed 9-2-2014

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name Davis Drilling and Pumps Contractor  
Address H/C 61 Box 54 Contractor  
Hiko Nevada 89017  
Nevada contractor's license number \_\_\_\_\_  
Issued by the State Contractors Board 0028966  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
Signed Mike Davis  
By driller performing actual drilling on site or contractor  
Date 9-8-2014

USE ADDITIONAL SHEETS IF NECESSARY

37.3833222  
-115.1595469  
NAD  
27