

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120717
Permit No. _____
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37260

1. OWNER JUNE WHEELER ADDRESS AT WELL LOCATION 6611 S PAULA DR PAHRUMP
MAILING ADDRESS PO BOX 4189 PAHRUMP NV 89041-4189 Subdivision Name: MESA OESTE ESTATES County: NYE

2. LOCATION NE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec 14 T 21S R 53 E Latitude N36°07'23.4" UTM E NAD 27
PERMIT/WAIVER No. 44-732-03 Longitude W115°59'05.6" N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	45	45
CALICHIE		45	65	20
CLAY		65	80	15
CALICHIE		80	105	25
CLAY		105	135	30
CALICHIE	WB	135	165	30
CLAY		165	170	5
CALICHIE	WB	170	225	55
CLAY		225	230	5
CALICHIE	WB	230	240	10

DCNR/DWR/SNBO RECEIVED
AUG 19 2014

9. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>10</u> Inches	<u>0</u> Feet	<u>240</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2.37</u>	<u>.248</u>	<u>0</u>	<u>240</u>

Perforations:

Type of perforation SSCREEN
Size of perforation .032

From	feet to	feet	feet
<u>180</u>	<u>240</u>		

Annular Seal: Yes No

	to	Pumped	Poured
<input type="checkbox"/> Neat Cement		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout		<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 50 to 240 Pumped Poured

Type: _____
Bentonite Chips: Yes No _____ to _____ Pumped Poured

Type: _____

Date started: 9-Aug, 20 14
Date completed: 9-Aug, 20 14

7. Water Level
Static water level: 134' feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING Contractor
Address 1220 MANSE RD Contractor
PAHRUMP NV 89048

Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the 1426

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 8/11/2014

(Rev 05-09) USE ADDITIONAL SHEETS IF NECESSARY

Plugged original well (log # 70521)

36.1232035 NAD
-115.9840319 27