

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120720
Permit No. 43524
Basin 230

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36289

1. OWNER ROCKVIEW DAIRIES INC
MAILING ADDRESS PO BOX 70
AMARGOSA VALLEY NV 89020-0070

ADDRESS AT WELL LOCATION 852 E MECCA RD
AMARGOSA
Subdivision Name: _____ County: NYE

2. LOCATION NE 1/4 NE 1/4 Sec. 9 T. 17S R. 49E
PERMIT/WAIVER No. 43524 Parcel No. 19-381-13

Latitude N 36°29'67.3" UTM E NAD 27
Longitude W 116°26'99.0" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & LAGRE GRAVEL		0	110	110
SANDY CLAY & GRAVEL		110	130	20
SAND & SMALL GRAVEL		130	400	270
SAND/GRAVEL & ROCK		400	480	80
OTHER INFORMATION:				
MATERIAL USED: JOHNSON STAINLESS WIRE WRAPS .060 FROM 340' TO 280' FROM 260' TO 220'				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
480		480	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
28	0	57	
19	57	480	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	52.73	.250	0	57
14	36.71	.250	+1	480

Perforations:

Type of perforation	Size of perforation	From	to	feet	feet
		440	340		

Annual Seal: Yes No

Neat Cement to _____ Pumped Poured

Cement Grout to _____ Pumped Poured

Concrete Grout 0 to 480 Pumped Poured

≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 0 to 480 Pumped Poured

Type: _____

Bentonite Chips: Yes No to _____ Pumped Poured

Type: _____

Date started: 15-May , 20 14
Date completed: 15-May , 20 14

7. Water Level
Static water level: 107 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the reports true to the best of my knowledge.

Name GREAT BASIN DRILLING Contractor
Address 1220 MANSE Contractor
PAHRUMP NV 89048

Nevada contractor's license number issued by the State Contractor's Board 47383

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 6/10/2014

RECEIVED
2015 SEP 23 AM 9:08
ENGINEERS OFFICE