STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120837
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36839

1. OWNER Kady Corp
MAILING ADDRESS 19512 Pathway St. Suite B Santee, CA. 92071
ADDRESS AT WELL LOCATION 1929 N. Las Vegas Blvd N. Las Vegas, NV. 89030
Subdivision Name: County: Clark

2. LOCATION NW¼ SW¼ Sec 23 T 20 N OR 61 E
PERMIT/WAIVER No. 139-23-310047 Issued by Water Resources Parcel No.
Latitude N36°11'43.53" Longitude W115°07'47.59"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
Client well MW-3

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL SAND/GRAVEL		0	4	4
FILL Gravelly Sand		4	6	2
CLAYEY Sand		6	8	2
SANDY CLAY		8	11	3
CLAYEY SAND	yes	11	12	1
Sandy CLAY		12	14	2
CLAY/SAND	yes	14	25	11

CONFIDENTIAL RECEIVED MAY 1 8 2014

Date started: 4/28, 20 14
Date completed: 4/29, 20 14

7. Water Level
Static water level: 11 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 24½ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	25 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" sch	40 PVC	ASTM 480	0	24½

Perforations:
Type of perforation Factory Slots
Size of perforation 020
From 9.5 feet to 24.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	0 to 2		☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 7.5 to 24.5 ☐ Pumped ☒ Poured
Type: 3/8 Monterey Silica Sand
Bentonite Chips: ☒ Yes ☐ No 2 to 7.5 ☐ Pumped ☒ Poured
Type: 3/8 Hydrated Bentonite Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. Contractor
Address 4255 W. Post Rd. Contractor
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas M. Beall By driller performing actual drilling on-site or contractor
Date 5/8/14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.1954549
-115.1290513
NAD 27

(NSPO 3-08) (O) 627