

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120871
Permit No. 83144
Basin 029

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **69720**

1. OWNER Dufurena Lands LLC ADDRESS AT WELL LOCATION Near Denio HWY
MAILING ADDRESS 397 Denio Hwy 140 Denio, Nv
Winnemucca, Nv 89445 Subdivision Name: _____ County: Humboldt
2. LOCATION NW1/4 SW1/4 12 T-44N R-31E mdb&m Latitude 41.700447 N
PERMIT/WAIVER No. _____ Longitude 118.462476 W NAD83/WGS
Issued by Water Resources 83144 Parcel No. 4431-13-100-001

3. WORKED PERFORMED New 4. PROPOSED USE Stock water 5. WELL TYPE rotary

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, gravel, boulders		0	60	60
Silt, Sand & Gravel		60	155	95
Sand & gravel with silt / clay layers		155	485	330
		485	600	115
		600		

RECEIVED
214 SEP 19 AM 11:53
STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION

Depth Drilled 600 Feet Depth Cased 600

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 7/8</u> Inches	<u>0</u>	<u>600</u>
_____ Inches	_____	_____
_____ Inches	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>STEEL</u>	<u>.188</u>	<u>0</u>	<u>20</u>
<u>6.625</u>	<u>PVC</u>	<u>sd/21=.450 in</u>	<u>20</u>	<u>600</u>

Perforations:

Type of perforation 6 inch pvc mill horizontal slot screen

Size of perforation 1/32

From	feet to	To
<u>500</u>	<u>600</u>	<u>600</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Annular Seal: Yes

Neat Cement _____ to _____

Cement Grout 4 to 24 Poured

Concrete Grout _____ to _____

Bentonite pellets 24 to 150 Poured

Gravel Pack: Yes 150 to 600 Poured

Type: _____ 3/8 minus _____

Bentonite Chips: _____ to _____ Poured

Type: _____ Barroid Hole plug _____

Date started: 1/30/2014
Date completed: 2/20/2014

7. Water Level
Static water level: 455 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COLD °F
Quality: good

8. WELL TEST DATA


TEST METHOD: Bailer Pump Air Lift x

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25</u>	<u>est 500</u>	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name High Desert Drilling LLC
Contractor _____
Address 4225 E Mary Way
Contractor _____
Winnemucca Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 62237
Nevada driller's license number issued by the Division of Water Resources, this on-site Miller 2364

Signed 
By driller performing actual drilling on site or contractor _____
Date 4/1/2014