STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120897
Permit No.
Basin No. 070

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70189
WELL NAME *(If applicable)*: N/A

1. OWNER/CLIENT NAME C. Tebeau & David C. Piquet
MAILING ADDRESS P.O. Box 71 Winnemucca, NV 89446

DETAILED ADDRESS AT WELL LOCATION Piquet Ranch
Subdivision Name: *County:* Humboldt

2. PLS LOCATION SE ¼ NW ¼ 2 Sec 36 N/S 38 E
PERMIT/WAIVER NO. 83482 *Issued by Water Resources* *Current Parcel No.*

Latitude 41* 01'42.16" N UTM E ☐ NAD 27
Longitude 117* 40' 19.34" W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☒ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand and Gravel			0'	60'	60'
Sand and Clay			60'	107'	47'
Volcanic Rock			107'	224'	117'

RECEIVED 2014 SEP 26 AM 10:59 STATE ENGINEERS OFFICE

NAD 27
41.028476°N
117.671078°W

Date started: 3-Sep, 20 14
Date completed: 6-Sep, 20 14

7. WATER QUALITIES
Static water level: 30' Feet below land surface
Artesian Flow: No G.P.M. 0 P.S.I.
Water Temperature: Cold ° Fahrenheit
Water Quality: N/A

8. WELL TEST DATA
Test Method: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Constant	1200	7.7'	6 Hours

9. WELL CONSTRUCTION
Depth Drilled: 224' Feet Depth Cased: 224' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26"	Inches	0'	Feet	107'	Feet
17.5"	Inches	107'	Feet	224'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20"		.375"	+1'	107'
12 3/4"		.250"	+2'	224'

PERFORATIONS:
Type of perforation: Mill Slot
Size of perforation: 0.080"
From 100' Feet To 224' Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal		to		
☐ Neat Cement	0'	to 107'	☒ Pumped	☐ Poured
☒ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	0'	to 224'	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Stonehouse Drilling and Construction, LLC. *Contractor*
Address 7801 Lakeside Drive Reno, NV 89511 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 0069994
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* # 1713
Signed: *By driller performing actual drilling on site or contractor*
Date: 9-25-14

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY