

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 120899  
Permit No. \_\_\_\_\_  
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71335  
WELL NAME (if applicable): Triple T

1. OWNER/CLIENT NAME BTAZ Nevada LLC  
MAILING ADDRESS 224 North Park Ave, Fremont, NE 6802

DETAILED ADDRESS AT WELL LOCATION Big Smokey Valley, NV

2. PLS LOCATION NW 1/4 SW 1/4 20 Sec 15 N/S 44 E  
PERMIT/WAIVER NO. 005-171-03  
Issued by Water Resources Current Parcel No.

Subdivision Name: \_\_\_\_\_ County: Nye  
Latitude 39.14402 UTM E  NAD 27  
Longitude 117.06671 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # unknown  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Mining / Dewater  Test / Other  
 Irrigation  Com / Ind  Mun / QM  
 Monitor  Stock  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	5
Sand/Gravel			5	25
Brown Clay			25	31
Sand/Gravel			31	65
Brown Clay			65	67
Sand/Gravel			67	240

9. INSTRUCTION  
Depth Drilled: 240 Feet Depth Cased: 240 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 240  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.96	.188	+2	240

ANNULAR MATERIALS  
Sanitary Seal x  Yes  No  
 Neat Cement 5 to 105  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack [ > 0.2 in. ] 105 to 240  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 22-Jul, 20 14  
Date completed: 25-Jul, 20 14

PERFORATIONS:  
Type of perforation: Mill Slot  
Size of perforation: 0.09  
From 120 Feet To 240 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

7. WATER QUALITIES  
Static water level: 21 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Parsons Drilling, Inc. Contractor  
Address P.O. Box 1265 Fallon, NV 89406 Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

Nevada contractor's license number as issued by the State Contractor's Board: \_\_\_\_\_  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): \_\_\_\_\_  
Signed: Walter Parsons  
Date: 9-19-2014  
By order performing actual drilling on site or contractor

RECEIVED  
2014 SEP 26 AM 10:58  
STATE ENGINEERS OFFICE  
2285

(Rev. 12-13)

USE ADDITIONAL SHEETS IF NECESSARY

pg. \_\_\_\_\_ of pg. \_\_\_\_\_

Replacing Unknown Well log