STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120904
Permit No.
Basin No. 102

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72409
WELL NAME (if applicable):

1. OWNER/CLIENT NAME LEON & JEANNE PARK
MAILING ADDRESS 3230 E 7TH ST
SILVER SPRINGS NV 89249

DETAILED ADDRESS AT WELL LOCATION 3230 7th street
Silver Springs Nv 89249
Subdivision Name: Lahonton Sub #2 County: Lyon

2. PLS LOCATION SE ¼ NW ¼ 16 Sec 17N N/S 25 E
PERMIT/WAIVER NO. 017-352-13
Issued by Water Resources Current Parcel No.

Latitude 39-33947 UTM E ☐ NAD 27
Longitude -119.18842 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other ☐

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
sand, brown clay			0	20
brown clay, sand, gravel			20	30
brown clay			30	60
sand, gravel			60	63
brown clay			63	120
grey clay			160	178
sand gravel			178	190
Brown Clay			190	195
grey clay			195	200
sand gravel			200	219
TID 219				
		NAD 27		
		39.339823		
		119.1874 27		

RECEIVED 2014 SEP 24 AM 11:28 STATE ENGINEERS OFFICE

Date started: 8-Sep , 20 14
Date completed: 12-Sep , 20 14

9. CONSTRUCTION
Depth Drilled: 219 Feet Depth Cased: 219 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	55	Feet
8 1/2	Inches	55	Feet	219	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+3	219

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0 to 55	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ Bentonite Chips	to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	55 to 219	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured
☐ Other, explain:	to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY
Size of perforation: 3/32 X 3

From	Feet	To	Feet
179	Feet	219	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 60 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25+		2 hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name A.S.A.P.Pump & Well Service,LLC.
Contractor
Address P.O. Box 60130 Reno, Nevada 89506
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2362
Signed Larry Welch
(by driller performing actual drilling on site or contractor)
Date 9/12/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.