

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72192

1. OWNER Steve Bird ADDRESS AT WELL LOCATION 1105 Roseway CC NV
 MAILING ADDRESS 733 Meadow Lane CC NV
 2. LOCATION SW 1/4 SE 1/4 Sec. 05 T. 14 N/S R 20 E Carson County
 PERMIT NO. Dom 14-55 Issued by Water Resources Parcel No. 009-311-39 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	1	1
Clay		1	5	4
SAND - gravel		5	8	3
BROWN SAND		8	65	57
Clay - SAND		65	184	119
SMALL Gravel		184	220	38
39' 06" 174				
119' 45" 585				
Rad 27				
3910 2991 2				
119.75 9737 CW				

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12</u>	<u>.187</u>	<u>12</u>	<u>20</u>
<u>6"</u>	<u>.4</u>	<u>SOR21</u>	<u>20</u>	<u>220</u>

Perforations:
 Type perforation factory Screen
 Size perforation .040
 From _____ feet to _____ feet
 From 180 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 62 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 62 feet to 220 feet

9. WATER LEVEL
 Static water level 82' feet below land surface
 Artesian flow NA G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality clear

Date started 8-20-14, 20____
 Date completed 8-8-14, 20____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>404</u>	<u>-</u>	<u>3 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
PO Box 1255
 Address Carson City, NV 89702
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 46498A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2137
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date August 15 2014