Well #2

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120992
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72091

1. OWNER Beth Collobert + Cathy Mumper
MAILING ADDRESS P.O. BOX 0464
Graham WA 98338

ADDRESS AT WELL LOCATION Not Given Yeat
Subdivision Name:
County: Pershing

2. LOCATION SE ¼ SE ¼ Sec 10 T 34 N/S R 37 E
PERMIT/WAIVER No. 009-080-13
Issued by Water Resources
Parcel No.

Latitude
Longitude
UTM E 432713 ☒ NAD 27
N 4519865 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	
Gravel		5	10	
Sand + Gravel		10	20	
Clay		20	45	
Brown Clay		45	55	
Sand + Gravel		55	70	
Rocky Clay		70	85	
Sand + Gravel		85	120	
NAD 27				
40.823555°N				
117.797919°W				

Date started: 10-9, 2014
Date completed: 10-16, 2014

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation Saved
Size of perforation 3/16 x 3
From 90 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 5 to 25 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 80 to 120 ☐ Pumped ☒ Poured
Type: 3/8
Bentonite Chips: ☒ Yes ☐ No 25 to 80 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 18 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	100+	Unk	1 Hr.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC.
Contractor
Address P.O. BOX 902 - Winnemucca, NV 89446
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0009605A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807
Signed Joe Boggio
By driller performing actual drilling on site or contractor Joe Boggio
Date

RECEIVED 2014 NOV 13 PM 2:23 STATE ENGINEERS OFFICE

(Rev 06-08)

USE ADDITIONAL SHEETS IF NECESSARY