

DRMW-015

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120997
Permit No.
Basin No. 054

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71751
WELL NAME (If applicable): DRMW-015

1. OWNER/CLIENT NAME BARRICK CORTEZ
MAILING ADDRESS HCL60 Box 1250 CRESENT
VALLEY, NV 89921

DETAILED ADDRESS AT WELL LOCATION N/A
Subdivision Name:
County: EUREKA

2. PLS LOCATION SW 1/4 SW 1/4 27 Sec 29 0S 49 E
PERMIT/WAIVER NO. mo-1923A
Issued by Water Resources Current Parcel No.

Latitude UTM E 547379 NAD 27
Longitude UTM N 4466132 NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [] Deepen: Orig Well#
[] Replacement: Original well log #
[] Recondition: Original well log #

4. PROPOSED USE
[] Domestic
[] Mining / Dewater
[] Test / Other
[] Irrigation
[] Com / Ind
[] Mun / QM
[X] Monitor
[] Stock
[] Rec

5. WELL TYPE
[] Auger [] Rotary [] RVC
[] Air [] Mud [X] Sonic
[] Other

LITHOLOGIC LOG table with columns: Material Encountered, Lost Circ., Water Strata, From, To. Includes entries like Tan silt, orange sandy silt & gravel, etc.

9. INSTRUCTION
Depth Drilled: 80 Feet
HOLE DIAMETER (BIT SIZE)
From To
8" 0 80
Inches Feet
Inches Feet
Inches Feet

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet). Includes entry: 4" Sch 80 0 50

ANNULAR MATERIALS
Sanitary Seal [X] Yes [] No
[] Neat Cement to [] Pumped [] Poured
[] Cement Grout to [] Pumped [] Poured
[X] Concrete Grout 0 to 2 [] Pumped [X] Poured
[X] Bentonite Chips 2 to 45 [] Pumped [X] Poured
[] Gravel Pack [> 0.2 in.] to [] Pumped [] Poured
[X] Sand Pack [4/8"] 45 to 80 [] Pumped [X] Poured
[] Other, explain: to [] Pumped [] Poured

PERFORATIONS:
Type of perforation: FACTORY CUT
Size of perforation: .020
From 50 Feet To 80 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

Date started: 8/21 20 14
Date completed: 8/22 20 14

7. WATER QUALITIES
Static water level: 44.5 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name BOART LONGYEAR Contractor
Address 605 Union Pacific Way Eureka NV 89801 Contractor

8. WELL TEST DATA table with columns: Test Method, G.P.M., Draw Down (Feet Below Static), Recorded Time (Hours). Includes entry: Pumped 2.5 0 6 hrs

Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2270-m
Signed: [Signature]
Date: 9-20-14
By driller performing actual drilling on site or contractor