STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121003
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71337
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Mike Kuras
MAILING ADDRESS 7737 Curry Rd. Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 7737 Curry Rd. Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION sw ¼ sw ¼ 35 Sec 18 N/S 28 E
PERMIT/WAIVER NO. *Issued by Water Resources* 006-553-15 *Current Parcel No.*

Latitude 39.37648 UTM E ☐ NAD 27
Longitude 118.8157 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand/Gravel			0	8
Green Clay			8	21
Gray Clay			21	26
Black Clay w/Sand			26	32
Black Sand			32	40
Black Clay w/Sand			40	86
Gray Clay			86	108
Black Clay w/Sand			108	126
Gray/White Gravel		X	126	132
NAD 27				
39.376582°N				
118.814775°W				

Date started: 3-Sep , 20 14
Date completed: 6-Sep , 20 14

9. CONSTRUCTION
Depth Drilled: 132 Feet Depth Cased: 132 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	+2	Feet	132	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	18
6	4	.316	18	132

ANNULAR MATERIALS

Sanitary Seal ☐ Yes ☐ No

☒ Neat Cement	5	to 105	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	105	to 132	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:

Type of perforation: Saw Cut
Size of perforation: 0.125

From	To
127 Feet	132 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

7. *WATER QUALITIES*
Static water level: 11 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O. Box 1265 Fallon, NV 89406 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2285
Signed: *By driller performing actual drilling on site or contractor*
Date: 10-6-14

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

Replaces unknown well log