STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121067
Permit No.
Basin OUU

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72242

1. OWNER Veris Gold USA, Inc.
MAILING ADDRESS HC 31 Box 75, ELKO NV 89801

ADDRESS AT WELL LOCATION Jerritt Canyon Mine
Subdivision Name:
County: ELKO

2. LOCATION SW ¼ SE ¼ Sec 4 T 40 N/S R 54 E
PERMIT/WAIVER No. NEV00000020 (Issued by Water Resources) Lot 31 (Parcel No.)

Latitude 41.387037
Longitude -115.898241
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Silt Gravel | Dry | 0 | 27 | 27 |
| Brown Clay with Silt | Dry | 27 | 82.5 | 55.5 |
| Brown Silt Gravel | Dry | 82.5 | 110 | 27.5 |
| PZ-7 | | | | |
| Pad 27 | | | | |
| 41.387128 N | | | | |
| 115.897326 W | | | | |

Date started: 6/20/14, 20 14
Date completed: 6/21/14, 20 14

7. Water Level
Static water level: Dry feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

9. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 110 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | Sch 40 | +2 | 110 |
| | | | | |

Perforations:
Type of perforation Factory Slot
Size of perforation .010
From 30 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 26 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 28 to 110 ☐ Pumped ☒ Poured
Type: 16/20 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 26 to 28 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. (Contractor)
Address PO Box 940 Meridian, ID. 83680 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2246

Signed (By driller performing actual drilling on-site or contractor)
Date 7/9/14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627