STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121102
Permit No. 82896T
Basin 072

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70141

1. OWNER Tim Delong Family Trust
MAILING ADDRESS P.O. Box 367
Imlay NV 89419

ADDRESS AT WELL LOCATION 7 miles West of Imlay NV
Subdivision Name:
County: Pershing

2. LOCATION SW ¼ SW ¼ Sec 33 T 33 N/S R 33 E
PERMIT/WAIVER No. 82896 T 008-150-40
Issued by Water Resources Parcel No.

Latitude 40-40-37.34 N
Longitude 118-16-26-46 W
UTM E
N
■ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ■ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	2	2
Hard green clay, sand	NO	2	52	50
Hard green clay, sand	Yes	52	300	248

RECEIVED
2014 NOV 18 AM 11:08
STATE ENGINEERS OFFICE

Nad 27
40.677039°N
118.274017°W

Date started: 6-27, 20 14
Date completed: 7-3, 20 14

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Sched 40	20	300

Perforations:
Type of perforation Slot
Size of perforation .20
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 300 ☐ Pumped ■ Poured
Type: 3/8" Pea gravel
Bentonite Chips: ■ Yes ☐ No 20 to 50 ☐ Pumped ■ Poured
Type: 3/8" chip

7. Water Level
Static water level: 52 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	NA	8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd.
Contractor
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 7-15-14

(Rev 05-05)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627