STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121155
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37765
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Jay T. Ewing
MAILING ADDRESS 1400 N. A Street
Las Vegas, NV

DETAILED ADDRESS AT WELL LOCATION 1300 N A Street
Las Vegas, NV
Subdivision Name: County: Clark

2. PLS LOCATION NW ¼ NE ¼ 27 Sec 20 N/S 61 E
PERMIT/WAIVER NO. _____ Issued by Water Resources
139-27-501-007 Current Parcel No.

Latitude 36.18519 UTM E ☒ NAD 27
Longitude 115.14223 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Gravel & Sand			0	3
Caliche			3	7
Clay with Gravel		x	7	32

DCNR/DWR/SNBC
RECEIVED
AUG 2 1 2014

Date started: 7-10, 20 14
Date completed: 7-10, 20 14

7. WATER QUALITIES
Static water level: 21 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality: NA

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 32 Feet Depth Cased: 32 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	32	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	30

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout	2	to	26	☐ Pumped	☒ Poured
☐ Bentonite Chips	26	to	29	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	29	to	32	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

Bentonite Chips - Poured from 135 to 76' 8" Borehole

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.01

From	Feet	To	Feet
30		32	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP
Contractor
Address 5241 Schrills St. Las Vegas NV 89118
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 00735355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2492

Signed: Richard L Ewing
By driller performing actual drilling on site or contractor
Date: 8-7-14

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.