

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**  
Log No. 121162  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in accordance with NRS 524.170 and NAD 524.340*

NOTICE OF INTENT NO. 70005

1. OWNER NEAL BRADY ADDRESS AT WELL LOCATION 520 W LUPIN ST  
MAILING ADDRESS PO BOX 421  
MICHIGAN CITY, IN. 46361-0421 Subdivisor Name: U8B CALVADA VLY County: NYE

2. LOCATION SE 1/4 NW 28 Sec 28 T 20S R 53E Latitude N 36°11'11.1" UTM E  NAD 27  
PERMIT/WAIVER No. 39-071-18 Longitude W 116°01'22.6" N  NAD 83/WGS 84  
Parcel No. \_\_\_\_\_

3.  New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	28	28
CALICHIE		28	35	7
CLAY		35	76	41
CALICHIE	WB	76	88	12
CLAY		88	110	22
CALICHIE	WB	110	125	15
CLAY		125	140	15
CALICHIE	WB	140	165	25
CLAY		165	210	45
CALICHIE	WB	210	240	30
CLAY		240	260	20

9. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE'S DIAMETER (BIT SIZE)

	From	To
<u>12</u> Inches	<u>0</u> Feet	<u>260</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.78</u>	<u>.280</u>	<u>0</u>	<u>260</u>

Perforations:

Type of perforation SCREEN  
Size of perforation .032

From 160 feet to 260 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 50  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 50 to 260  Pumped  Poured  
Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 27-May, 2014  
Date completed: 27-May, 2014

7. Water Level  
Static water level: 76 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING  
Contractor

Address 1220 MANSE RD  
Contractor

PAHRUMP NV 89048

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 47333

Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the 1426

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 5/29/2014