STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121169
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37253

1. OWNER MICHAEL & JEANETTE DACKO
MAILING ADDRESS 36505 OAKRIDGE DR
YUCAIPA CA 92399

ADDRESS AT WELL LOCATION 2420 E LEWIS ST
PAHRUMP
Subdivision Name: CONESTOGA County: NYE

2. LOCATION NE ¼ NW ¼ Sec 13 T 21S N/S R 53 E
PERMIT/WAIVER No. 44-591-03
Issued by Water Resources Parcel No.

Latitude N 36°07'51.0"
Longitude W 115°58'02.5"
UTM E ☐ NAD 27
N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 8" STEEL WELL		6	100	100
CLAY		100	110	10
CALICHIE	WB	110	125	15
CLAY		125	145	20
CALICHIE	WB	145	165	20
CLAY		165	195	30
CALICHIE	WB	195	235	40
CLAY		235	240	5

DCNR/DWR/SNBC RECEIVED JUN 1 8 2014

Date started: 13-Jun , 20 14
Date completed: 13-Jun , 20 14

7. Water Level
Static water level: 84 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	100	Feet
7-7/8	Inches	100	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	0	100
4.5	2.37	.248	0	240

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 160 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 240 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the 1426
Signed
By driller performing actual drilling on site or contractor
Date 6/10/2014

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.1308702
-115.9665043
NAD 27