STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 121207
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37790
WELL NAME (If applicable): MW-1

1 OWNER 7-Eleven Jose Rios
MAILING ADDRESS PO Box 711 Dallas TX 75221

ADDRESS AT WELL LOCATION 3995 E. Sunset Rd
Henderson NV
Subdivision Name: County: Clark

2 LOCATION NW ¼ NE ¼ Sec 6 T 22S N/S R 62 E
PERMIT/WAIVER No. 178-06-501-005 (Issued by Water Resources) Parcel No.
Latitude 36° 4" 14.66" N
Longitude 115° 5' 14.81" W
UTM E ☒ NAD 27
N ☐ NAD 83/WGS 8

3 TYPE OF WELL
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

Is this well being plugged because a replacement well was drilled? No
If yes, what is replacement well NOI?

Is there an existing well log?
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	2.01	4.500	0	25

Existing Perforations:
Type of perforation Factory
Size of perforation 0.02

From	feet to	feet
10	25	feet
		feet
		feet
		feet
		feet

5 WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

6 Additional Notes or Comments

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? ☒ yes ☐ no
If well was not cleaned out to total depth, please explain why:

Was the well contaminated? ☐ yes ☒ no
Was the casing pulled? ☒ yes ☐ no If pulled from: 0 feet to 25 feet
Was the casing over drilled? ☐ yes ☒ no
If casing was left in place, please show where additional perforations were made:

Additional Perforations:
Type of perforater used:

From	feet to	feet	Number of perfs per linear foot

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	Pumped	Poured
0	1		Concrete	☐	☒
1	25		Neat Cement	☒	☐
				☐	☐
				☐	☐
				☐	☐
				☐	☐

Neat Cement Fluid Weight 15 lbs/gal
Bentonite Grout 5 % bentonite

Date Started 25-Sep
Date Completed 25-Sep

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 5241 Schirls Street-Las Vegas, NV 89118 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 00735355
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057
Signed (By driller performing actual drilling on site or contractor)
Date 10/10/2014

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

DCNR/DWR/SNBO
RECEIVED
OCT 20 2014

36.070738
-115.0874472
NAD 27