STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121299
Permit No.
Basin No. 153

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71700
WELL NAME (If applicable): P-11

1. OWNER/CLIENT NAME Barrick Ruby Hill
MAILING ADDRESS Highway 50 + SR 278
P.O. Box 676 Eureka NV 89316

DETAILED ADDRESS AT WELL LOCATION Intersection of Highway 50 + SR 278 - Diamond Valley
Subdivision Name: County: Eureka

2. PLS LOCATION NW¼ SW ¼ 10 Sec 19 N/S 53 E
PERMIT/WAIVER NO. M/10 1936
Issued by Water Resources Current Parcel No.

Latitude UTM E 586358 ■ NAD 27
Longitude UTM N 4375918 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ■ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ■ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
waste dump			0	90
Gravels			90	180
Bed Rock / Sands		x	180	800
NAD 27				
39.530461°N				
115.4951890°W				

Date started: 10/19, 20 14
Date completed: 10/24, 20 14

7. WATER QUALITIES
Static water level: 700 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: good - clean, clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
4		10 hrs

9. CONSTRUCTION
Depth Drilled: 800 Feet Depth Cased: 800 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	90	Feet
8 1/2	Inches	90	Feet	800	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		.250	0	90
4		Schedule 80	+2'	800

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
■ Bentonite Chips	0	to 728	☐ Pumped	■ Poured
■ Gravel Pack [> 0.2 in.]	778	to 800	■ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
■ Other, explain: Coated Pellets	728	to 778	■ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Slotted
Size of perforation: .032

From	Feet	To	Feet
780		800	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear Company (Contractor)
Address PO Box 2748 Elko, NV. 89803 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): M 2262
Signed: Frank Stephens (By driller performing actual drilling on site or contractor)
Date: 11/12/14

RECEIVED 2014 NOV 21 AM 11:03 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.