STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121300
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72324

1. OWNER Uriel Cisneros
MAILING ADDRESS 7005 Germain Ave. Winnemucca NV.
ADDRESS AT WELL LOCATION 9355 Betty Ln. Winnemucca NV.
Subdivision Name: County: Humboldt

2. LOCATION SW ¼ NW ¼ Sec 30 T 35 N/S R 38 E
PERMIT/WAIVER No. 3538-30-100-0141
Issued by Water Resources Parcel No.
Latitude N 40° 52.927
Longitude W 117° 45.138
UTM E N
■ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
■ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Existing 6 5/8" well	NO	0	180	180
Gravel sand clay	YES	180	300	120

Nad 27
40.882117°N
117.752300°W
deepens unknown log

Date started: 9-17, 20 14
Date completed: 9-23, 20 14

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8"	Inches	180	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½	PVC	Sched 40	180	300

Perforations:
Type of perforation Slot
Size of perforation .20
From 160 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ■ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 177 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	NA	6

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76278
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature] By driller performing actual drilling on-site or contractor
Date 11-14-14

RECEIVED 2014 NOV 20 AM 11:02 STATE ENGINEER'S OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

(Rev 08-08)

(NSPO 3-08) (O) 627