STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121309
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68375
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Steve Brown
MAILING ADDRESS PO Box 812 GV NV
NW

DETAILED ADDRESS AT WELL LOCATION 962 Edna GV NV
Subdivision Name: *County:* Douglas

2. PLS LOCATION ~~SW~~ ¼ NW ~~SW~~ ¼ 17 Sec 12 N/S 20 E
PERMIT/WAIVER NO. 1220-17-101-01P
Issued by Water Resources *Current Parcel No.*

Latitude 38° 54.462 UTM E ☐ NAD 27
Longitude 119° 46.090 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand			0	8	8
Multi colored sand			8	17	9
Sand & gravel			17	62	45
Rock			62	66	4
hard muti colored rock			66	94	28
Medium Gravel-clay			94	122	28
Med gravel			122	178	56

RECEIVED
2013 JUN 11 AM 11:32
STATE ENGINEERS OFFICE

NAD27
38.907793°N
119.767156°W

Date started: 5-Jun, 20 13
Date completed: 6-Jun, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 178 Feet Depth Cased: 178 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	178	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	+1	20
6		SDR21	20	178

PERFORATIONS:
Type of perforation: Factory Screen
Size of perforation: 0.09
From 138 Feet To 178 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal 0 to 100
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout 0 to 100 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] 100 to 178 ☐ Pumped ☒ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 4 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25+		1.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling
Contractor
Address Po Box 1255 CC Nv 89702
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 46498
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2134

Signed: [signature]
By driller performing actual drilling on site or contractor
Date: June 11 2013

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY