STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121318
Permit No. 83580
Basin 108

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71295

1. OWNER Joe & David Sceirine Ranch
MAILING ADDRESS PO Box 1013 Yerington NV 89447

ADDRESS AT WELL LOCATION Well #1
Subdivision Name: N/A County: Lyon

2. LOCATION SW¼SW¼ Sec28T14N/ R25E
PERMIT/WAIVER NO. 83580 (Issued by Water Resources) N/A (Parcel. No.)

Latitude 39.04335 UTM E ☐ NAD 27
Longitude 119.18695 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	10	10
Clay		10	14	4
Sand-course		14	30	16
Gravel	X	30	50	20
Clay		50	52	2
Gravel/Sand	X	52	90	38
Clay		90	100	10
Gravel w/clay streamers	X	100	140	40

NAD27
39.043132°N
119.185963°W

RECEIVED
2014 NOV 26 AM 11:31
STATE ENGINEER'S OFFICE

Date started: Oct 30, 20 14
Date completed: Nov 3, 20 14

7. Water Level
Static water level: 35 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		5

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8.0	.188	+18"	140

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32x4
From 110 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 95 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 95 to 100 ☐ Pumped ☒ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date Nov 20, 2014

Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com