STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121332
Permit No.
Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71995

1. OWNER Jean Thomas
MAILING ADDRESS PO Box 31 Paradise Valley, NV

ADDRESS AT WELL LOCATION Paradise Valley
Subdivision Name: County: Humboldt

2. LOCATION NW¼SE¼ Sec8T42N/ R40E (SW)
Latitude 41.32'00.9" UTM E ☐ NAD 27
Longitude 117.29'49.8" N ☒ NAD 83/WGS 84

PERMIT/WAIVER NO. N/A (Issued by Water Resources) 4240-17-100-001 (Parcel. No.)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/Clay		0	15	15
Gravel & Clay streamer		15	105	85
Fine sand/gravel		105	140	35
3/4 Gravel		140	160	20
Sand/fine gravel		160	220	60
Course gravel	X	220	270	50
Sand/fine gravel	X	270	290	20

NAD 27
41.533688°N
117.496204°W

RECEIVED NOV 25 PM 1:13 STATE ENGINEER'S OFFICE

Date started: November 5, 20 14
Date completed: November 7, 20 14

7. Water Level
Static water level: 105 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		4

9. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	290 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+18"	290

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32 X 4
From 250 feet to 290 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 4 to 55 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 55 to 290 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date November 25, 2014

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com