

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
 Log No. 121337
 Permit No. _____
 Basin 089

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72434

1 OWNER Northwind Construction Services
 MAILING ADDRESS 1425 Higham St Idaho Falls, ID 83402

ADDRESS AT WELL LOCATION Washoe Valley

2 LOCATION SW ¼ SW ¼ Sec 26 T 17N N/S R 19 E
 PERMIT/WAIVER No. WL140072
Washoe Co. Issued by Water Resources Parcel No. _____

Subdivision Name: _____ County: Washoe
 Latitude 39.30541 UTM E NAD 27
 Longitude -119.82315 N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no
 If yes, what is replacement well NOI? _____

Is there an existing well log? no
 If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
 Depth Drilled 14 Feet Depth Cased 14 Feet

7 WELL PLUGGING PROCEDURE
 Was well cleaned out to total depth? yes no
 If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3	7.58	.216	0	14

Was the well contaminated? yes no
 Was the casing pulled? yes no
 Was the casing over drilled? yes no

Existing Perforations:
 Type of perforation unknown
 Size of perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

If casing was left in place, please show where additional perforations were made:
 Additional Perforations:
 Type of perforator used: None
 From _____ feet to _____ feet Number of perfs per linear foot _____
 From _____ feet to _____ feet Number of perfs per linear foot _____
 From _____ feet to _____ feet Number of perfs per linear foot _____
 From _____ feet to _____ feet Number of perfs per linear foot _____
 From _____ feet to _____ feet Number of perfs per linear foot _____
 From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
 Static water level 3'6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	Material Used	
0	14	Neat Cement	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured
		Neat Cement	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
		Neat Cement	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
		Neat Cement	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
		Neat Cement	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
		Neat Cement	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

6 Additional Notes or Comments
Pulled the casing and pumped neat cement in as casing was pulled.

Neat Cement Fluid Weight 15.6 lbs/gal
 Bentonite Grout _____ % bentonite
 Date Started 11/19/2014
 Date Completed 11/19/2014

RECEIVED BY
 DIVISION OF WATER RESOURCES
 STATE ENGINEERS OFFICE

NAD 27
39.305500°N
119.822130°W

9 DRILLER'S CERTIFICATION
 This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed Wayne Ramsey
 Date 11-20-14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

Plugging Unknown Well log