STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121347
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72636

1. OWNER Ray Walther
MAILING ADDRESS 7760 Flintlock Rd. Winnemucca NV.
ADDRESS AT WELL LOCATION 7760 Flintlock Rd. Winnemucca NV.
Subdivision Name: Paradise Ranchos County: Humboldt

2. LOCATION SE ¼ NW ¼ Sec 31 T 40 O/S R 39 E
PERMIT/WAIVER No. 4039-31-100-012
Issued by Water Resources Parcel No.
Latitude N41° 18.327
Longitude W117° 37.940
UTM E
N
■ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	4	4
clay sand gravel	NO	4	40	36
sand gravel clay	Yes	40	150	110

RECEIVED 2014 DEC -4 PM 12:07 STATE ENGINEERS OFFICE

NAD 27
41.305450°N
117.632333°W

Date started: 11-6, 20 14
Date completed: 11-8, 20 14

9. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	10
6 5/8	PVC	Sched 40	10	150

Perforations:
Type of perforation Slot
Size of perforation .20
From 110 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 150 ☐ Pumped ■ Poured
Type: 3/8" Pea
Bentonite Chips: ■ Yes ☐ No 20 to 50 ☐ Pumped ■ Poured
Type: 3/8" Chip

7. Water Level
Static water level: 40 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	NA	4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 11-12-14

USE ADDITIONAL SHEETS IF NECESSARY

(Rev 05-03)

(NSPO 3-08)

(O) 627