STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121349
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72637

1. OWNER Mike Thompson / Dennis Ballew
MAILING ADDRESS P.O. Box 3022
Winnemucca NV.

ADDRESS AT WELL LOCATION 6325 Mills Rd.
Winnemucca NV.
Subdivision Name: County: Humboldt

2. LOCATION SE ¼ SE ¼ Sec 12 T 35 O/S R 37 E
PERMIT/WAIVER No. ~~3735~~ 12476-002
Issued by Water Resources 3537 Parcel No.

Latitude N 40°55.09885
Longitude W 117°45.57176
UTM E
N
■ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
■ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
existing well	No	0	125	125
clay gravel sand	Yes	125	225	100

RECEIVED 2014 DEC -4 PM 2:06 STATE ENGINEERS OFFICE

NAD27
40.918314°N
117.759529°W

Date started: 11-15- , 20 14
Date completed: 11-17 , 20 14

7. Water Level
Static water level: 120 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8"	Inches	125	Feet	225	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½	PVC	Sched 40	105	225

Perforations:
Type of perforation Slot
Size of perforation .20
From 105 feet to 225 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ■ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd.
Contractor
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 11-18-14

(Rev 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627