STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121377
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37803
WELL NAME *(If applicable)*: MW-10

1. OWNER/CLIENT NAME 7-Eleven / Jose Rios
MAILING ADDRESS PO Box 711 Dallas TX 75221

DETAILED ADDRESS AT WELL LOCATION 1285 E. Reno Ave
Las Vegas, NV 89119
Subdivision Name: *County:* Clark

2. PLS LOCATION SW ¼ NW ¼ 26 Sec 21 N/S 61 E
PERMIT/WAIVER NO. 162-26-210-015
Issued by Water Resources *Current Parcel No.*

Latitude 36* 5' 49.56" N UTM E
Longitude 115* 8' 8.66" W UTM N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	4"
TYPE II Base			4"	10"
Gravely silt sand some cobbels			10"	4'
Caliche			4'	12.5"
Gravellt silt subgangular gravels			12'5"	20
Silty w/gravel coarse gravels wet			20'	25.5"

DCNR/DWR/SNRC
RECEIVED
NOV 17 2014

Date started: 30-Oct , 20 14
Date completed: 30-Oct , 20 14

7. *WATER QUALITIES*
Static water level: 15' 5" Feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. *INSTRUCTION*
Depth Drilled: 26 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4"	Inches	0	Feet	25.5"	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.500	2.01	0.237	0	25

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement	0	to	2	☐ Pumped	☒ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips	6	to	8	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	8	to	25	☐ Pumped	☒ Poured
☐ Other, explain: Bentonite Grout	2	to	6	☐ Pumped	☒ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	10	Feet	To	25	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP
Contractor
Address 5241 Schirlls Street, Las Vegas, NV 89118
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 00735355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2512
Signed: Bob
By driller performing actual drilling on site or contractor
Date: 11/14/14

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

36.09710
-115.135738

NAD 27