

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 121411  
Permit No. \_\_\_\_\_  
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71896  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Steve Moore  
MAILING ADDRESS 255 East Corkhill  
Fallon NV 89406

DETAILED ADDRESS AT WELL LOCATION 255 East Corkhill  
Fallon NV 89406  
Subdivision Name: \_\_\_\_\_ County: Churchill

2. PLS LOCATION SE 1/4 NW 1/4 19 Sec 18 N/S 29 E  
PERMIT/WAIVER NO. 006-811-17  
Issued by Water Resources Current Parcel No.

Latitude \_\_\_\_\_ UTM E 0346967  NAD 27  
Longitude \_\_\_\_\_ UTM N 4363897  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Corn / Ind  Stock  
 Test / Other  Mun / QM  Rec  Other

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Top Soil			0	1	1
Brown Sands			1	14	13
brown clay			14	20	6
brown sands			20	40	20
brown clay			40	43	3
Grey Sands		X	43	70	27
black silt clays			70	100	30
Grey Sands			100	115	15
Grey clay			115	118	3
brown Sands		X	118	130	12

9. WELL CONSTRUCTION

Depth Drilled: 130 Feet Depth Cased: 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>100</u> Feet
<u>6 5/8</u> Inches	<u>100</u> Feet	<u>130</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>0</u>	<u>130</u>

PERFORATIONS:

Type of perforation: machine slot  
Size of perforation: .080  
From 123 Feet To 128 Feet

ANNULAR MATERIALS

Sanitary Seal \_\_\_\_\_ to \_\_\_\_\_  
 Neat Cement 0 to 100  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 15 %  20 %  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 11-24 20 14  
Date completed: 11-25 20 14

7. WATER QUALITIES  
Static water level: 28 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: OK

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Welcoo drilling corp  
Address P.O. Box 888 Fallon NV 89406

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>2</u>	<u>2</u>

Nevada contractor's license number as issued by the State Contractor's Board: 11752  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2199  
Signed: Jesus Mainer  
Date: 12-3-14

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY

Replacing Unknown Well log