

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121475
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37268

1. OWNER GREGORY DAUN ADDRESS AT WELL LOCATION 80 E FALCON
MAILING ADDRESS 80 E FALCON PAHRUMP
PAHRUMP NV 89048 Subdivision Name U4 CALVADA VLY County NYE

2. LOCATION SW 1/4 SW 1/4 Sec 34 T 20S N 36 R 53 E Latitude N36°9'49.28" UTM E NAD 27
PERMIT/WAIVER No. 40-701-21 Longitude W116°0'4.3" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Monitor
 Municipal/Industrial Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
EXISTING 8" STEEL WELL		0	140	140
CLAY		140	155	15
CALICHIE	WB	155	160	5
CLAY		160	180	20
CALICHIE	WB	180	185	5
CLAY		185	220	35
CALICHIE	WB	220	235	15
CLAY		235	255	20
CALICHIE	WB	255	265	10
CLAY		265	285	20
CALICHIE	WB	285	300	15

DCNR/DWR/SNBC
RECEIVED
NOV 12 2014

Original well log # 58724

9. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
EXISTING	0	140
7-7/8	140	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	0	140
4.5	2.37	.248	0	300

Perforations:

Type of perforation SCREEN
Size of perforation .032

From 200 feet to 300 feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 140 to 300 Pumped Poured

Bentonite Chips: Yes No to _____ Pumped Poured

Date started: 31-Oct, 20 14
Date completed: 31-Oct, 20 14

7. Water Level
Static water level: 84 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING
Contractor

Address 1220 MANSE RD
Contractor

PAHRUMP NV 89048

Nevada contractor's license number 47333
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 11/10/2014