STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121481
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34603
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Kris Johnson,Rosemary Truesdale & At
MAILING ADDRESS 2090 Traci St.
Pahrump, NV 89048

DETAILED ADDRESS AT WELL LOCATION
2731 W. Guinn Ct. Pahrump, NV 89048
Subdivision Name: Parcel 1 *County:* Nye

2. PLS LOCATION SE ¼ NW ¼ 6 Sec 20-S N/S 53 E
PERMIT/WAIVER NO. 36-012-35
Issued by Water Resources *Current Parcel No.*

Latitude N36° 14.545' UTM E 2558' ☐ NAD 27
Longitude W116° 03.801' UTM N 16' ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Surface			0	4
Brown Clay/Granulated caliche			4.	17
Brown Clay			17	32
Gray Clay			32	54
Brown Clay			54	72
Brown Clay/Caliche			72	83
Brown Clay		X	83	180

DCNR/DWR/SNBC
RECEIVED
NOV 07 2014

Date started: 28-Oct ,20 14
Date completed: 31-Oct ,20 14

7. WATER QUALITIES
Static water level: 62 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 180 Feet Depth Cased: 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4"	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	3.92	.28	0	180

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
■ Concrete Grout	0	to 50	☐ Pumped	■ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
■ Gravel Pack [> 0.2 in.]	50	to 180	☐ Pumped	■ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/4" width 3" long

From	140 Feet	To	180 Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Jim Pike Well Drilling, LLC
Contractor
Address P. O. Box 56 Pahrump, NV 89041
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 17563A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1324

Signed: Jim Pike
By driller performing actual drilling on site or contractor
Date: 11/01/14

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.2425459
-116.0624293
NAD 27