

Plugging

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121492
Permit No. 70839
Basin 117

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32998

1. OWNER White Mtn. Ranch
MAILING ADDRESS 144 West Esplanade, Box 21, George, UT, 84790

ADDRESS AT WELL LOCATION _____
Subdivision Name: _____ County: Esmeralda

2. LOCATION NE SE 1/4 Sec 15 T 35 N/S R 35 E
PERMIT/WAIVER No. 70839
Issued by Water Resources Parcel No. _____

Latitude N 37° 40.735' UTM E NAD 27
Longitude W 118° 04.083' N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other Abandon-plug

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG
Material Water Strata From To Thickness
Red Cement
in well. Discovered
it was 110 feet deep
with total cut casing
10" hole was dry no
water.
pumped 24% Bentonite
Grout Back to 20' ft
then pumped neat
Cement Back to surface.

9. WELL CONSTRUCTION
Depth Drilled 110' Feet Depth Cased 110' Feet
HOLE DIAMETER (BIT SIZE)
From To
Inches Feet Feet Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
10" 10' weight 0 110'

Perforations
Type of perforation Teeth Cut
Size of perforation 3/16 x 6"
From 0 feet to 110' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 0 to 20' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 24% Bentonite Grout 10 to 110' Pumped Poured
Gravel Pack: Yes No _____ to _____ Pumped Poured
Type: _____
Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

Date started: Sept 21, 20 14
Date completed: Sept 22, 20 14

7. Water Level
Static water level: DRY feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)
DCNR/DWR/SNBO RECEIVED
OCT 01 2014

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jack Drilling Contractor
Address PO Box 3699 Contractor
Silver Springs, UT 84729
Nevada contractor's license number 31881
issued by the State Contractor's Board
Nevada driller's license number issued by the 1876
Division of Water Resources, the on-site driller
Signed Richard J. Paul
By driller performing actual drilling on-site or contractor
Date Sept 24, 2014

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

37.678989 NAD
-118.0671043 27 (C) 627