STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121531
Permit No. 11797
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72437
WELL NAME (*If applicable*): Stillwater

1. OWNER/CLIENT NAME Plouviez, Paul (Bench Creek Ranch)
MAILING ADDRESS P.O Box 1315 Kings Beach, CA 96143-1315

DETAILED ADDRESS AT WELL LOCATION Stillwater Rd
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION NW ¼ NW ¼ 33 Sec 20 N/S 32 E
PERMIT/WAIVER NO. 11797 (*Issued by Water Resources*) (*Current Parcel No.*)

Latitude 39.56081 UTM E ☐ NAD 27
Longitude -118.40463 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☒ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	4
Brown Sand			4	16
Brown Clay			16	21
Black Gravel			21	47
Sand/Gravel			47	59
Boulders/Sand		X	59	93
White Clay/Sand			93	100
NAD 27				
39.560891°N				
118.403658°W				

Date started: 14-Nov, 20 14
Date completed: 15-Nov, 20 14

7. WATER QUALITIES
Static water level: 47 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
50		2

9. INSTRUCTION
Depth Drilled: 100 Feet Depth Cased: 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 3/4 Inches		0 Feet	100 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.96	.188	+2	20
8	6.69	.411	20	100

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0 to 50	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ Bentonite Chips	to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50 to 100	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured
☐ Other, explain:	to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8.
From 70 Feet To 90 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 Fallon, NV 89406 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2509
Signed: (*By driller performing actual drilling on site or contractor*)
Date: 11/18/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replaces Unknown Well log