STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121536
Permit No.
Basin No. 103

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71804
WELL NAME (If applicable): MW-2

1. OWNER/CLIENT NAME Superior Campgrounds of America
MAILING ADDRESS dba Silver City RV Park
265 N Joy St St 200 Corona, CA

DETAILED ADDRESS AT WELL LOCATION Facility ID: 2-000075
3165 N US Highway 395 Minden, NV 89423 Douglas
Subdivision Name: County: ~~Washoe~~

2. PLS LOCATION NW ¼ NW ¼ 19 Sec 14 N/S 20 E
PERMIT/WAIVER NO. M/O-1952 (Issued by Water Resources) 1420-00-002-001 (Current Parcel No.)

Latitude 39.06925752 UTM E ☒ NAD 27
Longitude -119.7792381 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Dry greenish brown			0	20	20
rocky clay					

Date started: 6 Nov, 20 14
Date completed: 6 Nov, 20 14

7. WATER QUALITIES
Static water level: 17 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled: 20 Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		Sch 40	0	20

PERFORATIONS:
Type of perforation: Slot
Size of perforation: 0.04
From 10 Feet To 20 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to		
☒ Neat Cement	0	to 6	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	6	to 8	☐ Pumped	☒ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	8	to 20	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3000 Duluth Street West Sacramento, CA 95691 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 73966
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1991
Signed: (By driller performing actual drilling on site or contractor)
Date: 12/1/14

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY