STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121546
Permit No.
Basin 087

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72520

1. OWNER Marsh Family Trust
MAILING ADDRESS 5210 Ventana Pkwy
Reno NV 89511

ADDRESS AT WELL LOCATION 11210 Vincent Ln
Reno NV 89511
Subdivision Name: County: Washoe

2. LOCATION SW ¼ NE ¼ Sec 13 T 18N / R 19 E
PERMIT/WAIVER NO. 040-740-09
Issued by Water Resources Parcel. No.

Latitude 39.426453 UTM E ☐ NAD 27
Longitude -119.797432 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders, Cobbles, Sand, Gravel & Brown Clay		0	100	100
Cobbles, Sand, Gravel, Brown Clay		100	125	25
Sand, Gravels & Brown Clay		125	200	75

Washoe County Permit
WL140076.

Nad 27
39.426542 N
119.79641 ccw

replace rentmann bay

Date started: 12/9, 20 14
Date completed: 12/11, 20 14

7. Water Level
Static water level: 96 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	30+		2

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	200

Perforations:
Type of perforation Factory
Size of perforation .060 double row
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 200 ☐ Pumped ☒ Poured
Type: 1/4 x 1/8
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [signature]
By driller performing actual drilling on site or contractor
Date 12/12/14

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com