WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 121554
Permit No.
Basin 179

NOTICE OF INTENT NO. 72478

1. OWNER Rod Conners
MAILING ADDRESS PO Box 966
McGill Nevada 89318

ADDRESS AT WELL LOCATION North Creek Road

2. LOCATION NE ¼ SW ¼ Sec. 20 T. 19 N/S R. 65 E. White Pine County

PERMIT NO. (Issued by Water Resources) 010-71-023 (Parcel No.) Quiett Family Trust (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt & Rock		0	4	4
Rock & Dirt		4	45	41 ft
Gravel	✓	45	46	1
Rock & Dirt		46	48	2
Rock & Dirt		48	120	72
Gravel	✓	120	121	1
Rock & Dirt		121	122	1
Gravel & Rock	✓	122	128	6
Rock & Dirt		128	135	7
Gravel & Rock	✓	135	138	3
Rock & Dirt		138	160	22
Gravel & Rock	✓	160	162	2
Rock & Dirt		162	165	3
Gravel & Rock	✓	165	167	2
Rock & Dirt		167	173	6
Gravel & Rock	✓	173	175	2
Rock & Dirt		175	193	18
Gravel & Rock	✓	193	195	2
Rock & Dirt		195	200	5
		NAD 27		
		39.499112°N		
		114.689068°W		

RECEIVED 2014 DEC 17 AM 10:00 STATE ENGINEERS OFFICE

Date started 11-05-3, 2014
Date completed 11-12, 2014

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	100	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.3	.250	0	20
6.625	4.95	Schedule 120	20	200

Perforations:
Type perforation Factory Saw
Size perforation .032
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100 ft
Placement Method: ☑ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 105 feet to 200 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow 0 G.P.M. 0 P.S.I.
Water temperature 57.3 °F Quality 225 TDS, 8.9 PH

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name David Gibson Contractor LLC (Contractor)
Address PO Box 203, Lund Nevada 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0077887

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2315

Signed Dennis H Eldridge
By driller performing actual drilling on site or contractor

Date 12-2-2014

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627