STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121568
Permit No.
Basin No. 087

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71803
WELL NAME *(If applicable)*: MW-2

1. OWNER/CLIENT NAME Karen Wener CW County Terrace LLC
MAILING ADDRESS 43 S Moonbeay Way
Eagle, ID 83616

DETAILED ADDRESS AT WELL LOCATION
11 Tuck Circle Reno, NV 89506
Subdivision Name: *County:* Washoe

2. PLS LOCATION SE ¼ NW ¼ 4 Sec 20N N/S 19E E
PERMIT/WAIVER NO. MO-1955 *Issued by Water Resources* 086-416-23 *Current Parcel No.*

Latitude 39.631098 N UTM E ☐ NAD 27
Longitude -119.858128 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Clay, Stiff, light brown			0	40	40
Clay, stiff, dark brown			40	90	50
Clay, semi-silty			90	103	13

RECEIVED 2014 DEC 19 AM 11:14 STATE ENGINEERS OFFICE

NAD 27
39.631189°N
119.857101°W

Date started: 10-Nov, 20 14
Date completed: 10-Nov, 20 14

9. WELL CONSTRUCTION
Depth Drilled: 103 Feet Depth Cased: 103 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	103	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	103

PERFORATIONS:
Type of perforation: Slot
Size of perforation: 0.011
From 28 Feet To 103 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to			
☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	21	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	21	to	26	☐ Pumped	☒ Poured
☐ Bentonite Grout		to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:					
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	26	to	103	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 55 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling, L.P. *Contractor*
Address 3000 Duluth Street West Sacramento, CA 95691 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 73966
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* M-2467
Signed: *By driller performing actual drilling on site or contractor*
Date: December 8, 2014

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY