

VE-3

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 121543  
Permit No.  
Basin 087

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70114

1. OWNER Farland Properties Corp 7-11 Inc  
MAILING ADDRESS PO box 711 Dallas TX 75221

ADDRESS AT WELL LOCATION 1680 Silverado Blvd, Reno

Subdivision Name: Truckee Meadows County: Washoe

2. LOCATION SE 1/4 SW 1/4 Sec 6 T 19 S R 70 E  
PERMIT/WAIVER No. MO-1959 008-073-01  
Parcel No.

Latitude 39.5449621 UTM E 260699.01  NAD 27  
Longitude -119.78248848 N 4380900.77  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	6"	6"
Silt sand w/ gravel		6"	5'	4 1/2'
Same as above		5'	10'	5'
Well graded gravel		10'	15'	5'
gravel w/ sand		15'	20'	5'
poorly graded sand w/ gravel		20'	25'	5'
gravelly sand		25'	30'	5'
Same as above		30'	35'	5'

9. WELL CONSTRUCTION  
Depth Drilled 35 Feet Depth Cased 35 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 35 Feet  
6 1/2 inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>Sch 40</u>	<u>0</u>	<u>35</u>

Perforations:  
Type of perforation slotted  
Size of perforation .010  
From 20 feet to 35 feet

Annular Seal:  Yes  No  
 Neat Cement 16' to 1'  Pumped  Poured  
 Cement Grout  Pumped  Poured  
 Concrete Grout  Pumped  Poured  
 ≥30% Bentonite Grout  Pumped  Poured  
Gravel Pack:  Yes  No 35' to 18'  Pumped  Poured  
Type: 2 1/2" Filter sand  
Bentonite Chips:  Yes  No 18' to 16'  Pumped  Poured  
Type: medium

Date started: Dec 1st, 20 14  
Date completed: Dec 1st, 20 14

7. Water Level  
Static water level: \_\_\_\_\_ feet below land surface  
Artesian Flow: N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water Temperature: N/A °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Gross Drilling & Testing Contractor  
Address 950 Howard rd North Las Vegas NV 89153 Contractor  
Nevada contractor's license number 38113  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 24388  
Division of Water Resources, the on-site driller  
Signed [Signature]  
By driller performing actual drilling on-site or contractor  
Date 12.17.14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY