

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121592
Permit No. _____
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 08361
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Anne E. McDonald DETAILED ADDRESS AT WELL LOCATION 2410 Chipmunk DR
MAILING ADDRESS 2410 Chipmunk DR Washoe Valley
Washoe Valley Subdivision Name: _____ County: Washoe
2. PLS LOCATION NE 1/4 NE 1/4 31 Sec 17 N/S 20 E Latitude 39.29993 UTM E NAD 27
PERMIT/WAIVER NO. OSD-364-03 Longitude 119.77113 UTM N NAD 83/WGS 84
Issued by Water Resources Current Parcel No.

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____
4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec
5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Sand			0	11	11
DG 8 Cobbles			11	20	9
Sands & Gravels			20	68	48
Cobbles			68	73	5
Gravels			73	89	16
Soft Brown Gravel			89	95	6
Brown Gravel			95	130	35
Black & White Gravel Frag			130	195	65
Black & White Fine Gravel			195	203	8
Black & White Gravel			203	217	14

9. WELL CONSTRUCTION
Depth Drilled: 217 Feet Depth Cased: 217 Feet
HOLE DIAMETER (BIT SIZE)
From To
11 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 200 Feet
8 5/8 Inches 200 Feet 217 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8 0.188 +2 17
6 5/8 SDR 21 17 217
PERFORATIONS:
Type of perforation: Factory
Size of perforation: 3/32
From 197 Feet To 217 Feet
From 157 Feet To 177 Feet
From _____ Feet To _____ Feet

ANNULAR MATERIALS
 Sanitary Seal 0 to 54 Pumped Poured
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 54 Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] 54 to 217 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

7. WATER QUALITIES
Static water level: _____ Feet below land surface
Artesian Flow: None G.P.M. 25+ P.S.I.
Water Temperature: Cold ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA

Test Method:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<u>175</u>			<input checked="" type="checkbox"/>	<u>25+</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: BLAIN DRILLING & PUMP CO INC.
Address: P.O. Box 1255
Carson City, NV 89702
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 46498A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2321
Signed: C. Robinson
By driller performing actual drilling on site or contractor
Date: 11-14-14