STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 121614
Permit No.
Basin No. 104

NOTICE OF INTENT NO. 69807
WELL NAME (*if applicable*): MW-6

1. OWNER/CLIENT NAME 7-Eleven, Inc
MAILING ADDRESS PO Box 711 Dallas TX 75221

DETAILED ADDRESS AT WELL LOCATION 3083 HW 50 East, Carson City
Subdivision Name:
County: Carson City

2. PLS LOCATION ¼ NE ¼ SE Sec 9 N/S 15 E
PERMIT/WAIVER NO. MO-1911 (Issued by Water Resources) 008-163-07 (Current Parcel No.)

Latitude 39.175986 UTM E
Longitude 119.733633 UTM N
[x] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [x] Monitor
[ ] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[x] Auger [ ] Rotary [ ] RVC
[ ] Air [ ] Mud [ ] Sonic
[ ] Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand with sand & gravel			.5	5
Gravel w silt and sand			5	6
Well graded sand w gravel			6	10
Gravel w silt & sand			10	15
Well graded sand w silt/ water 18'			15	19
Well graded sand w silt			19	24
Silty sand			24	25

Date started: 18-Nov, 20 13
Date completed: 18-Nov, 20 13

7. WATER QUALITIES
Static water level: 13 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: [x] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 25 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	10 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch. 40	-6	10

ANNULAR MATERIALS
Sanitary Seal x [ ] Yes [ ] No

[x] Neat Cement	1 to 7	[x] Pumped	[ ] Poured
[ ] Cement Grout	to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout	to	[ ] Pumped	[ ] Poured
[ ] Bentonite Chips	7 to 9	[ ] Pumped	[x] Poured
[ ] Gravel Pack [> 0.2 in.]	9 to 25	[ ] Pumped	[x] Poured
[ ] Sand Pack [< 0.2 in.]	to	[ ] Pumped	[ ] Poured
[ ] Other, explain:	to	[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: Factory mill slot
Size of perforation: 20
From 10 Feet To 25 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 2086 E. Main St., Woodland, CA 95767 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2113
Signed: (By driller performing actual drilling on site or contractor)
Date: 11-9-14

RECEIVED 2015 JAN 12 STATE ENGINEER'S OFFICE

(Rev. 12-13)
USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Plugged by well log 121615