STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121629
Permit No.
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72976
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME SCOTT SUMMER
MAILING ADDRESS 840 WASHOE DRIVE
CARSON CITY, NV 89704

DETAILED ADDRESS AT WELL LOCATION 840 WASHOE DRIVE
CARSON CITY, NV 89704
Subdivision Name: *County:* Washoe

2. PLS LOCATION NE ¼ SE ¼ 23 Sec 17 N/S 19 E
PERMIT/WAIVER NO. DOM 14-65 *Issued by Water Resources* 050-232-03 *Current Parcel No.*

Latitude 39.318956*N UTM E ☐ NAD 27
Longitude 119.813613*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 25312
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 6 5/8 WELL			+2	120
GREEN DG SAND AND GRQVEL			120	165
GRAY CLAY			165	173
DG SAND AND GRAVELS		XXX	173	220

NAD 27
39.319046°N
119.812593°W

Date started: 12-Jan , 20 15
Date completed: 13-Jan , 20 15

9. CONSTRUCTION
Depth Drilled: 100 Feet Depth Cased: 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	120	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	3.96	.216	100	220

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	N/A	to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY SLOT
Size of perforation: 0.032

From	Feet	To	Feet
180	Feet	220	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 25 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 56° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30	40	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. *Contractor*
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed: Michael Hack *By driller performing actual drilling on site or contractor*
Date: 1/14/2018

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Deepens Well log 25312