STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121630
Permit No.
Basin No. 103

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72970
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME TED AND DIANE CONKLIN
MAILING ADDRESS 7160 IRON MTN BLVD
STAGECOACH, NV 89429

DETAILED ADDRESS AT WELL LOCATION 7160 IRON MTN BLVD
STAGECOACH, NV 89429
Subdivision Name: *County:* Lyon

2. PLS LOCATION NW ¼ NW ¼ 18 Sec 17 N/S 23 E
PERMIT/WAIVER NO. 015-325-08
Issued by Water Resources *Current Parcel No.*

Latitude 39.343313*N UTM E ☐ NAD 27
Longitude 119.448913*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 64463
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 6 5/8 WELL			0	160
OBSIDIAN SANDS			160	195
OBSIDIAN VOLCANIC SANDS AND GRAVELS		XXX	195	260

NAD 27
39.343398°N
119.447909°W

Date started: 7-Jan , 20 15
Date completed: 9-Jan , 20 15

9. INSTRUCTION
Depth Drilled: 100 Feet Depth Cased: 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	160	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	3.96	.216	140	260

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement	N/A	to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From	Feet	To	Feet
220	Feet	260	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 125 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 52° ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	45	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board*: 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 1905
Signed: Michael Black
By driller performing actual drilling on site or contractor
Date: 1/10/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Deepens Well log 64463